

## ANALYTIC APPROACH FOR HUMAN RELIABILITY ANALYSIS OF NUCLEAR RESEARCH REACTORS IN ASEAN REGION

Wasin Vechgama<sup>1\*</sup>, Weerawat Pornroongruengchok<sup>1</sup>, Saensuk Wetchagarun<sup>1</sup>, Anantachai Pechrak<sup>1</sup>, Kampanart Silva<sup>2</sup>, Jinkyun Park<sup>3</sup>

<sup>1\*</sup>Thailand Institute of Nuclear Technology (Public Organization), 16 Vibhavadi Rangsit Road, Chatuchak, Bangkok, 10900, Thailand

<sup>2</sup>National Energy Technology Center, National Science and Technology Development Agency, 114 Thailand Science Park, Phahonyothin Road, Khlong Nueng, Khlong Luang, Pathum Thani, 12120, Thailand


<sup>3</sup>Korea Atomic Energy Research Institute, 111, Daedeok-daero 989 Beon-gil, Yuseong-gu, Daejeon, 34057, Republic of Korea

### EXTENDED ABSTRACT


Nowadays, digital Instrumentation & Control (I&C) systems are increasingly being implemented in nuclear facilities as human-machine interfaces [1, 2]. These digital systems serve as the core system of nuclear facilities providing operators with monitoring and safety functions for abnormal events as well as automatic protection functions of the reactor core during potential accidents [3]. The transition from analogue system control to human-machine interfaces in the digital Main Control Room (MCR) can significantly impact the changes of crew roles, teamwork, and work performance [4]. Due to the influence of human factors on digital control systems, Human Reliability Analysis (HRA) has become an essential tool for identifying potential human errors and assessing their probabilities as data for regulatory and technical objectives [5].

Similarly, Nuclear Research Reactors (NRRs) in the Association of Southeast Asian Nations (ASEAN) are typically operated using I&C systems. Previously different HRA tools were applied to investigate human errors and estimate their probabilities. For example, Indonesia utilized the Human Factors Analysis and Classification System (HFACS) method to examine Type A human errors from operational experience data from the primary cooling system of the Reaktor Serba Guna G.A. Siwabessy (RSG-GAS) reactor [6]. Regarding the Puspiti TRIGA Reactor (PTR) of Malaysia, Type C human errors were analyzed and quantified using the Standardized Plant Analysis Risk Human Reliability Analysis (SPAR-H) method [7]. As for Thailand, the HRA team identified human errors in potential initiating events of the Thai Research Reactor-1/Modification 1 (TRR-1/M1) through expert judgment and a specific HRA method [8].

Since ASEAN countries operating NRRs plan to exchange HRA data, in 2023, the Thailand Institute of Nuclear Technology (TINT) proposed an HRA project to the ASEAN Network on Nuclear Power Safety Research (ASEAN NPSR) to jointly investigate the operating culture profile and develop and conduct HRA in the region based on the guideline of the Korea Atomic Energy Research Institute (KAERI) [9, 10]. Fig. 1 shows the results of ASEAN NRR operators' cultural profiles compared to operating cultures of commercial Nuclear Power Plant (NPPs) using Hofstede's model. The results of these two cases were oriented in similar directions. The operating cultures of ASEAN NRR operators and commercial NPPs are suitable for studying and sharing HRA data to each other.




**FIGURE 1. ASEAN NRR operators' cultural profiles compared to operating cultures of commercial NPPs using Hofstede's model (TH = Thailand, ML = Malaysia, IN = Indonesia, VN = Vietnam, PH = Philippines, US = United States, SE = Sweden, KR = South Korea)**




**FIGURE 2. HRA practical approach of HRA for NRRs**

Fig. 2 shows the HRA practical approach of HRA for NRRs [11]. In 2024, TINT and KAERI together developed a practical approach of HRA for NRRs to estimate prior Nominal Human Error Probabilities (NHEPs) from the Human Reliability data Extraction (HuREX) and updating observed human errors through the Empirical data-Based crew Reliability Assessment and Cognitive Error analysis (EMBRACE). However, the practical approach is not convenient to conduct HRA as an ASEAN NPSR benchmark problem due to the time and resource consumption. Hence, in this study, an analytic approach is suggested as an alternative HRA method to support the HRA benchmark project to support the practical approach. In the analytic approach, as ASEAN NRRs adhere to specific procedures and time for handling emergencies, the Task Complexity (TACOM) score is recommended to estimate NHEPs.



**FIGURE 3. INTERNATIONAL HRA BENCHMARK STUDY IN ASEAN NPSR**

Fig. 3 shows the scope of the international HRA benchmark study in ASEAN NPSR. To start the international HRA benchmark in ASEAN NRRs in ASEAN, HRA practitioners have to together discuss and select emergencies and accidents that possibly occur in general for NRRs. The complexity score of Emergency Operating Procedures (EOPs) of selected emergencies and accidents will be calculated using TACOM score [12]. The operators will be requested to provide the task performance time of the EOPs.



**FIGURE 4. CORRELATION BETWEEN TASK PERFORMANCE TIME AND TACOM SCORE OF NPPS**

Fig. 4 shows the correlation between task performance time and TACOM score [13]. The HRA implementors will check the correlation between task performance time and TACOM score. If the correlation is consistent with the empirical model of task performance time and TACOM score in Fig. 4. The overall TACOM scores of EOPs be used to estimate possible NHEPs based on the empirical model in Eq. (1) recorded unsafe act database of HuREX [14].

$$p(x) = \frac{1}{1 + e^{-(1.901x - 9.643)}} \quad (1)$$

where  $p(x)$  is the estimated probability of unsafe act and  $x$  is TACOM score.

## ACKNOWLEDGMENTS

The authors are grateful to the Thailand Institute of Nuclear Technology (TINT) and the ASEAN Network on Nuclear Power Safety Research (ASEAN NPSR) for providing important information to support this study. The authors also thank the Ministry of Higher Education, Science, Research, and Innovation (MHESI), Thailand, the Korea Atomic Energy Research Institute (KAERI), and the Korea National University of Science and Technology (UST) for their time and support during the publication process.

## REFERENCES

- [1] P. SINGH, L. K. SINGH, “Instrumentation and Control Systems Design for Nuclear Power Plant: An Interview Study with Industry Practitioners,” *Nuclear Engineering and Technology*, **53**, 11 (2021).
- [2] M. S. MINHAT, N. A. M. SUBHA, N. HAMZAH, A. R. HUSAIN, F. HASSAN, A. AHMAD, F. S. ISMAIL, “Hybrid MPC-P Controller for the Core Power Control System at TRIGA Reactor,” *Journal of Process Control*, **122** (2023).
- [3] J. PARK, T. KIM, S. KOO, “Verification Strategy for Artificial Intelligence Components in Nuclear Plant Instrumentation and Control Systems,” *Progress in Nuclear Energy*, **164**, 104842 (2023).
- [4] W. JUNG, Y. KIM, J. PARK, “A Time-reliability Correlation for Estimating the Diagnosis Error Probability of a Nuclear Power Plant with up-to-date Human-machine Interfaces,” *Nuclear Engineering and Technology*, **56**, 10 (2024).
- [5] I. S. KIM, “Human Reliability Analysis in the Man-machine Interface Design Review,” *Annals of Nuclear Energy*, **28**, 11 (2001).
- [6] S. SANTOSO, R. HIMAWAN, J. SITUMORANG, T. J. SURYONO, E. EDISON, “Reactor Operational Experience Review and Analysis based on un-intended Reactor Trip Data,” *Jurnal Teknologi Reaktor Nuklir Tri Dasa Mega*, **21**, 2 (2019).
- [7] A. HASSAN, M. MASKIN, P. PRAK TOM, F. BRAYON, P. HLAVAC, F. MOHAMED, “Operator Response Modeling and Human Error Probability in TRIGA Mark II Research Reactor Probabilistic Safety Assessment,” *Annals of Nuclear Energy*, **102**, (2017).
- [8] W. VECHGAMA, K. SILVA, A. PECHRAK, S. WETCHAGARUN, “Application of Hazard and Operability Technique to Level 1 Probabilistic Safety Assessment of Thai Research Reactor-1/Modification 1: Internal Events and Human Errors,” *Progress in Nuclear Energy*, **138**, 103838 (2021).
- [9] W. VECHGAMA, K. SILVA, J. YANG, J. PARK, “Initiating Risk Assessment Research Collaboration Between South Korea and ASEAN NPSR Member States,” *Asian Symposium on Risk Assessment and Management 2023*, Hong Kong, 4-6 December 2023.
- [10] W. VECHGAMA, J. PARK, S. WETCHAGARUN, A. PECHRAK, K. SILVA, “Systematic Preprocessing for Development of Human Reliability Analysis Framework of TRIGA Reactor,” *Asian Symposium on Risk Assessment and Management 2023*, Hong Kong, 4-6 December 2023.
- [11] W. VECHGAMA, J. PARK, S. WETCHAGARUN, A. PECHRAK, K. SILVA, “Development of a Human Reliability Analysis Framework for Nominal Human Error Probability Estimate of the TRIGA Research Reactor in Thailand,” *Nuclear Engineering and Technology*, **56**, 11 (2024).
- [12] J. PARK, “The Complexity of Proceduralized Tasks,” *Springer Series in Reliability Engineering* (2009).
- [13] I. JANG, Y. KIM, J. PARK, “Scrutinizing the Effect of Task Complexity on Operators’ Task Performance Time in a Digitalized Main Control Room of a Nuclear Power Plant,” *Nuclear Engineering and Technology*, **57**, 3 (2025).
- [14] I. JANG, J. PARK, “Determining the Complexity Level of Proceduralized Tasks in a Digitalized Main Control Room using the TACOM Measure,” *Nuclear Engineering and Technology*, **54**, 11 (2022).